HYDRODYNAMICS OF TWO-PHASE LOOP THERMOSYPHON

Wei Qu*

Institute of Engineering Thermophysics, Chinese Academy of Sciences, Beijing, 100190, China

ABSTRACT

Two-phase loop thermosyphons are important devices for large heat transport to a longer distance. The hydrodynamics of such device is closely related with the evaporator and condenser details. The evaporator is modeled by an integral balance of bubble flow, considering the relative velocity difference between the vapor and liquid. The condenser is calculated by liquid film condensation of vapor-liquid concurrent flow, corresponding to the two shear forces of viscous flow and momentum transfer. For the evaporator of one two-phase loop thermosyphon, the vapor bubble and liquid flow velocities, the axial density of the vapor-liquid mixture are formulated and analyzed. For the whole loop, the equivalent liquid position of operating evaporator, the driving liquid position difference between that in the liquid line and that of the evaporator equivalent, the liquid position difference in the liquid line before and after operating, are calculated and analyzed. The evaporator model and results can be referenced to the optimal design.

Keywords: *Two-phase loop thermosyphon, hydrodynamics, the vapor bubble and liquid flow velocities, the axial density of the vapor-liquid mixture, liquid position*

1. INTRODUCTION

The conventional heat pipe or non-loop thermosyphon each is self-contained, the adiabatic sections are not commonly designed long. They are suitable for short distance between the heat source and the heat sink, and the number of them is closely related with the power of heat transfer (Roesler, 1991; He, 1992).

Conveniently for some situations, two-phase loop thermosyphon has become highly efficient heat transfer element for a variety of applications (Huang, 1988, Chen, 1988). This type of arrangement completely decouples the evaporator and the condenser parts of the above-mentioned heat pipe or thermosyphon. Two major advantages are obtained compared to the classical heat pipe or thermosyphon, one is that the large distances between evaporator and condenser are easily

manageable, the other is that the mechanism opposite to the counter flow of conventional heat pipe or thermosyphon (Liu, 1988), the vapor and liquid flow co-currently.

Two-phase loop thermosyphons have been strongly propagated in the past few decades due to the high efficiency, reliability and cost-effectiveness. Devices of this type consist of separated assemblies of evaporator and condenser, which are connected by one or more common vapor and liquid lines, respectively. A schematic of a two-phase loop thermosyphon is given in Figure 1.

In the previous researches to the two-phase loop thermosyphon, the evaporator heat transfer and flow were mostly calculated by empirical formulae, the best filling rate was experimented to the real application.

Such as (Chen, 1986), for the evaporator assembly of a loop thermosyphon, the heat transfer coefficient is given as

$$h_e = 7.915q_e^{0.66} p_v^{0.06} \quad (1)$$

Where the heat flux and the vapor pressure should be within a scope respectively as, $0.503 < q_e < 3.5 \text{ W/cm}^2$; $0.045 < p_v < 1.63 \text{ Mpa}$. The accuracy of these methods is not good and if the structure and transferred power are varied, then the previous results are nearly useless.

It is commonly believed that the driving force of the condensation liquid return is the liquid position difference between that in the liquid return line and that of the evaporator. However, the liquid position of the evaporator is not obvious, since that the state of the evaporator is the mixture of vapor bubbles and the liquid.

When a thermosyphon works normally, many bubbles appear in the evaporator, this causes the rise of liquid pool surface. The increment of boiling liquid pool height is recommended as 30% of the original height. However, for a two-phase loop thermosyphon, this height

Fig. 1 Basic construction of a two-phase loop thermosyphon

* Corresponding author. Email: weiqu@iet.cn

increment is obviously not suitable due to the smaller diameter of evaporator tubes.

This work focuses on the two-phase loop thermosyphon. Firstly, the governing equations are given to describe the whole loop. Then, the evaporator is modeled to describe the flow and heat transfer of liquid and bubbles, the axial density of mixture is formulated. After that, the flow and heat transfer of the condenser, the vapor and liquid lines are considered theoretically together with the evaporator, and several liquid positions are calculated and discussed. Finally the results of liquid position difference is summarized and concluded.

2. THEORETICAL ANALYSES

The theoretical analysis is the following. The governing equations are established. The evaporator is modeled in every detail and particular, considering the relative speed between vapor and liquid. While for the condenser, the viscous friction force and momentum transfer force between vapor core and liquid film are considered.

2.1 Governing Equations

For a two-phase loop thermosyphon, the momentum of the evaporator, of the condenser, of the vapor and liquid lines has nearly the same type. The flow and heat transfer of the whole loop thermosyphon can be described by the continuum equation, the momentum equation and the heat transfer equation respectively as

$$\dot{m} = \rho u A \quad (2)$$

$$\frac{dp}{ds} = -\frac{\tau_w w}{A} - \frac{\dot{m}}{A} \frac{du}{ds} - \rho g \sin \theta \quad (3)$$

$$\dot{Q} = \dot{m} h_{fg} \quad (4)$$

Along the thermosyphon loop, for equation (3), there is

$$\oint dp = -\oint \frac{\tau_w w}{A} ds - \oint \frac{\dot{m}}{A} \frac{du}{ds} ds - \oint \rho g \sin \theta ds = 0 \quad (5)$$

For the vapor and liquid lines, during the vapor and liquid flowing, no phase change occurs, so the governing equations (2) and (3) apply. Equation (4) are only applied for the evaporator and the condenser.

Fig. 2 Evaporator modelling of a two-phase loop thermosyphon

Fig. 3 The forces function to the flowing bubble

2.2 Evaporator Modelling

The heat transfer in the evaporator belongs to the boiling in restricted space. The vapor-liquid mixture surface will be higher for more vapor bubbles. For the evaporator, the more vapor bubbles are, the less total working fluid are needed. The vapor upflow speed is much bigger than that of the liquid supply.

Considering the bubbles in the evaporator, as shown in Figure 2, the height of the vapor-liquid mixture is H , the bubbles in the micro control volume dh take time t to get to the surface. During time t , the total vapor volume is produced in dh section as

$$dV_v = t \frac{q \pi d_{in}}{h_{fg} \rho_v} dh \quad (6)$$

Where, t is the function of h . In order to find the function relation $t=h$, the bubble is assumed as globe, the radius is R , as illustrated in Figure 3.

For the vertical direction, the bubbles are controlled by the up-floating force and the liquid resistance, as shown in Figure 3. The upflow velocity is u . Then the vapor bubble momentum is written as

$$\frac{d}{dt} \left(\frac{4}{3} \pi R^3 \rho_v u \right) = \frac{4}{3} \pi R^3 g (\rho_l - \rho_v) - \frac{1}{2} \frac{d}{dt} \left(\frac{4}{3} \pi R^3 \rho_l u \right) \quad (7)$$

Equation (7) is simplified as

$$\frac{d}{dt} (R^3 u) = \frac{2(\rho_l - \rho_v)}{\rho_l + 2\rho_v} R^3 g \quad (8)$$

It is assumed that the radius of each dh does not change with time, and then there is

$$\frac{du}{dt} = \frac{2(\rho_l - \rho_v)}{\rho_l + 2\rho_v} g \quad (9)$$

Integrate equation (9) once, the velocity of vapor bubble at h is obtained as

$$u = \frac{2(\rho_l - \rho_v)}{\rho_l + 2\rho_v} g t + C_1 \quad (10)$$

At initial time, $t=0$, the velocity of vapor bubble, $u=0$, then, $C_1=0$.

$$u = \frac{2(\rho_l - \rho_v)}{\rho_l + 2\rho_v} g t \quad (11)$$

Integrate equation (11) once more, the relation of h to t is gotten

$$h = \frac{\rho_l - \rho_v}{\rho_l + 2\rho_v} g t^2 + C_2 \quad (12)$$

When $t=0$, $u=0$, $h=0$, there is, $C_2=0$.

$$h = \frac{1}{2} W t^2, \quad W = \frac{2(\rho_l - \rho_v)}{\rho_l + 2\rho_v} g \quad (13)$$

Then the relation of time t with height h is

$$t = \sqrt{\frac{2h}{W}} \quad (14)$$

Substitute equation (14) into equation (6), then integrate it

$$V_v = \frac{\pi d_{in} q}{h_{fg} \rho_v} \sqrt{\frac{2}{W}} \int_0^H \sqrt{h} dh = \frac{2}{3} \sqrt{\frac{2}{W}} \frac{\pi d_{in} q}{h_{fg} \rho_v} H^{\frac{3}{2}} \quad (15)$$

For the evaporator, the geometrical relations are as

$$V_l = \pi d_{in}^2 H_l / 4 \quad (16)$$

$$V_t = \pi d_{in}^2 H / 4 \quad (17)$$

$$V_t = V_v + V_l \quad (18)$$

Substitute equations (16)~(18) into equation (15), there is

$$\frac{8}{3} \sqrt{\frac{2}{W}} \frac{q}{h_{fg} \rho_v d_{in}} H^{\frac{3}{2}} + H_l - H = 0 \quad (19)$$

Equation (19) expresses the equivalent position H_l of vapor-liquid mixture in the evaporator. The mean velocity of vapor bubble at position h is also obtained as

$$\bar{u} = \frac{1}{H-h} \int_0^{H-h} \sqrt{2Wh} dh = \frac{2}{3} \sqrt{2W(H-h)} \quad (20)$$

The flow cross-section of vapor in the evaporator can be written as

$$A_{void} = \frac{q\pi D(H-h)}{h_{fg}\rho_v \bar{u}} = \frac{3}{2} \frac{\pi d_{in} q}{h_{fg}\rho_v} \sqrt{\frac{H-h}{2W}} \quad (21)$$

The mean liquid flow velocity is balanced by

$$\bar{u}_l = \frac{\pi d_{in} l_e q / h_{fg} - \bar{u} A_{void} \rho_v}{\rho_l (\pi d_{in}^2 / 4 - A_{void})} \quad (22)$$

So, at position h , the density of vapor-liquid mixture in the evaporator is

$$\rho_h = \frac{(A - A_{void}) \rho_l + A_{void} \rho_v}{A} = \rho_l - (\rho_l - \rho_v) \frac{3q}{d_{in} h_{fg} \rho_v} \sqrt{\frac{2(H-h)}{W}} \quad (23)$$

The dynamic viscosity of the vapor-liquid mixture in the evaporator can be calculated by the Cicchitti equation

$$\mu_m = x\mu_v + (1-x)\mu_l \quad (24)$$

Then the equivalent Reynolds number can be gotten to calculate the flow resistance.

2.3 Condenser Calculation

For a two-phase loop thermosyphon, the condensation heat transfer has many differences compared with those of classical Nusselt theory. The vapor flowing, the shear stress of the vapor-liquid interface should not be neglected.

Based on the Nusselt theory, the frictional shear stress and that of the momentum transfer due to the velocity difference between the vapor and liquid are added to the analysis of condensation and flow in the two-phase loop thermosyphon.

Fig. 4 Liquid film and vapor downward flows in the condenser.

As illustrated in Figure 4, the momentum equation of liquid film flow is given as

$$-\frac{dp}{dx} + (\rho_l - \rho_v)g + \mu_l \left(\frac{\partial^2 u_l}{\partial y^2} \right) = 0 \quad (25)$$

The energy equation becomes the following

$$\frac{\partial^2 T_l}{\partial y^2} = 0 \quad (26)$$

The boundary conditions are as follows

$$\text{At } y=0, u_l=0; T_l=T_w \quad (27)$$

$$\text{At } y=\delta, \left. \frac{\partial u_l}{\partial y} \right|_{y=\delta} = -\frac{\tau_v}{\mu_l}; T_l=T_v \quad (28)$$

Ignore the pressure gradient along the y direction, integrate equation (25), together consider equation (28)

$$\left[\frac{dp}{dx} - (\rho_l - \rho_v)g \right] (y - \delta) + \tau_v - \mu_l \left(\frac{du_l}{dy} \right) = 0 \quad (29)$$

Integrate equation (29), together consider boundary condition (27)

$$\left[\frac{dp}{dx} - (\rho_l - \rho_v)g \right] \left(\frac{y^2}{2} - \delta y \right) + \tau_v y - \mu_l u_l = 0 \quad (30)$$

So the liquid film velocity is expressed as

$$u_l = \frac{1}{\mu_l} \left[\frac{dp}{dx} - (\rho_l - \rho_v)g \right] \left(\frac{y^2}{2} - \delta y \right) + \frac{\tau_v y}{\mu_l} \quad (31)$$

Substitute $y=\delta$ into equation (31)

$$u_{l\delta} = \frac{1}{2\mu_l} \left[\frac{dp}{dx} - (\rho_l - \rho_v)g \right] \delta^2 + \frac{\tau_v \delta}{\mu_l} \quad (32)$$

Where τ_v is the shear stress between the flowing vapor and liquid due to two reasons. One is that of friction, τ_f , the other is from the momentum transfer owing to the condensation, τ_m .

$$\tau_v = \tau_f + \tau_m \quad (33)$$

$$\tau_f = \frac{1}{2} C_f (\bar{u}_v - \bar{u}_{l\delta})^2, \bar{u}_v > \bar{u}_{l\delta} \quad (34)$$

$$\tau_f = -\frac{1}{2} C_f (\bar{u}_v - \bar{u}_{l\delta})^2, \bar{u}_v < \bar{u}_{l\delta} \quad (35)$$

Where, the friction coefficient C_f depends on the vapor Reynolds number

$$\text{Re}_v = \frac{\rho_v |\bar{u}_v - \bar{u}_{l\delta}| d_v}{\mu_v} \quad (36)$$

$$C_f = 16/\text{Re}_v, \quad \text{Re}_v < 2000 \quad (37)$$

$$C_f = \text{Re}_v^{0.33}/1525, \quad 2000 < \text{Re}_v < 4000 \quad (38)$$

$$C_f = 0.079 \text{Re}_v^{-0.25}, \quad 4000 < \text{Re}_v < 30000 \quad (39)$$

$$C_f = 0.046 \text{Re}_v^{-0.2}, \quad 30000 < \text{Re}_v < 10^6 \quad (40)$$

$$\tau_m = \frac{q_c}{h_{fg}} (\bar{u}_v - \bar{u}_{l\delta}), \bar{u}_v > \bar{u}_{l\delta} \quad (41)$$

$$\tau_m = -\frac{q_c}{h_{fg}} (\bar{u}_v - \bar{u}_{l\delta}), \bar{u}_v < \bar{u}_{l\delta} \quad (42)$$

At the condenser entrance, the vapor velocity is maximum

$$\bar{u}_{\max} = \frac{4l_c q_c}{h_{fg} d_v \rho_v} \quad (43)$$

For the mass flow rate of liquid film, there is

$$\dot{m}_l = \int_0^\delta \rho_l 2\pi \left(\frac{d_{in}}{2} - y \right) u_l dy \quad (44)$$

$$\dot{m}_l = \frac{\pi d_{in} x q_c}{h_{fg}} \quad (45)$$

Consider equations (30), (44) and (45), there is

Fig. 5 Liquid positions before and after startup of a two-phase loop thermosyphon

$$\frac{4}{25} \left[\frac{dp}{dx} - (\rho_l - \rho_v) g \right] \delta^4 - \left\{ \frac{d}{6} \left[\frac{dp}{dx} - (\rho_l - \rho_v) g \right] + \frac{\tau_v}{3} \right\} \delta^3 + \frac{d\tau_v}{4} \delta^2 = \frac{v_l dx q_c}{2h_{fg}} \quad (46)$$

Based on equation (45), there is

$$\bar{u}_v = \frac{\dot{m} - \dot{m}_l}{\frac{\pi}{4} d_{in}^2 \rho_v} = \frac{4\dot{m}}{\pi d_{in}^2 \rho_v} - \frac{4xq_c}{d\rho_v h_{fg}} \quad (47)$$

The vapor flow diameter is given as

$$d_v = d_{in} - 2\delta \quad (48)$$

2.4 Vapor Line, Circular Liquid Film Line and Liquid Line Calculations

For the vapor line, the upward vapor flow is single phase, the mean vapor flow velocity is constant at each cross-section. Equation (3) becomes

$$\frac{dp}{ds} = -\frac{4\tau_w}{D} \pm \rho_v g \sin \theta \quad (49)$$

In equation (49), τ_w is the viscous force between the vapor and the tube wall.

$$\tau_w = \frac{C_f}{2} \rho_v \bar{u}_v^2 \quad (50)$$

In equation (50) C_f is calculated by equations (36)–(40).

The pressure loss includes local effect, that is calculated by the common fluid formula.

$$\Delta p_{local} = \frac{1}{2} \xi \rho_v \bar{u}_v^2 \quad (51)$$

Where, ξ is the local flow resistance coefficient.

The liquid line consists of the liquid film part and the single phase liquid part. Considering these two parts and the boundary, as illustrated in Figure 5, the working liquid position should be balanced by the operating conditions.

For the liquid film flow in the liquid line, the core vapor does not flow, the momentum equation becomes simple type as

$$\frac{dp}{ds} = \rho_v g \quad (52)$$

For the single phase liquid flow line, the inertial term is zero due to the constant liquid velocity.

$$\frac{dp}{ds} = -\frac{\tau_w P}{A} - \rho_l g \sin \theta \quad (53)$$

For the whole two-phase loop thermosyphon, the liquid amount of working fluid is selected just exactly the best filling. Then there is no excess working fluid to entrain the influential liquid, increase the flow resistance and worsen the heat transfer and flow.

3. RESULTS AND DISCUSSION

The calculation procedures are as follows. (1) Modeling of the evaporator. The heating tube is divided by n differential parts. The frictional coefficient of each evaporator cross-section is different, however, it is constant in each part. The vapor bubble velocity is calculated. Then the frictional pressure drop, the inertial pressure drop, the gravitational drop can be obtained. Further, the total liquid amount needed in the evaporator and the equivalent operating height H_l are determined. (2) Calculating of the condenser. Holding together equations (31)–(41), (46), (47) and (3), the frictional, inertial and gravitational pressure drops, and the total pressure drop are obtained. The total working fluid in condenser can be gotten by integrating the liquid film flow and the core vapor flow. (3) Calculating of the vapor line, liquid line and the local resistance. The liquid line consists of the liquid film flow line and the single liquid flow line. The latter is shown in Figure 5, the equivalent length is L'' . The length H_2 is first assumed, the original value can be a little increase of the previous obtained H_l . By increasing the height step many times, the circulation results are obtained and compared. The criteria to stop the calculation can be as,

the total flow resistance of the whole loop thermosyphon will be approaching zero very much by the last step increased. Then the several height positions, the related parameters could be analyzed.

3.1 Vapor-liquid Mixture of Evaporator

For evaporator, if the basic geometrical parameters are given, then the density of vapor-liquid mixture along the heating tube can be obtained by equation (23).

The length of the heating tube is 412mm, the inner diameter is 26mm and 20mm. Water is taken as the working fluid. The two-phase loop thermosyphon works at saturation temperature 100 °C. The thermosyphon is filled at the best filling rate, there is no excess liquid to increase the flow resistance. Three heat flux are selected as 21.5, 28.6 and 35.8 kW/m².

Fig. 6 Density of vapor-liquid mixture in evaporator as a function of heating tube height

Figure 6 shows the density distribution along the height. At the evaporator entrance, the liquid density is the initial. Along the upward direction, the vapor bubbles are increased more and more. So the density will decrease gradually. And for the higher heat flux, the density is smaller at the same cross-section. Such results mean that the higher heat flux corresponds to the less working fluid in the evaporator. These results could be used by the selection of the diameter and the length of the evaporator assembly. Another result is that at the exit of the evaporator, the density of the vapor-liquid mixture is not that of the vapor. It depends on the balance of the vapor bubble flow rate, that is, the phase change heat transfer. In order to guarantee that no dry-out point occurs, the heat flux should be less one boundary limit to the evaporator..

Fig. 7 Velocity of vapor in evaporator versus heating tube height

Figure 7 demonstrates the mean vapor bubble velocity at different axial position in the evaporator. The curve is like one parabolic shape. At the initial point, $x=0$, the velocity is zero. At the exit, $x=412$ mm, the mean bubble velocity $u_v=2.68$ m/s. And for different heat flux, the velocity curve is the same. Equation (20) also tells that the velocity is only related with axial position and the physical properties.

For the liquid flow in the evaporator, by equation (22), the velocity at different heat flux and different axial position is illustrated in Figure 8. Compared the results with those of Figure 7, the liquid velocity is three order quantity less than that of the vapor. So, the liquid flow velocity can nearly be neglected, no matter from the point of liquid flow resistance, or from the point of the comparison with that of the vapor. At the exit of the evaporator, the liquid velocity is zero. And for the lower heat flux, the liquid velocity is smaller. However, the axial maximum liquid velocity will move forward a little, that is the vapor-liquid equilibrium.

Fig. 8 Velocity of liquid in evaporator versus heating tube height

3.2 Three Liquid Positions and Two Heights

As shown in Figure 5, actually there are three liquid positions. Before the operating of the two-phase loop thermosyphon, there is a filling liquid position. The other two liquid positions should be calculated. One of them is the equivalent working liquid position in the operating evaporator. The other one, the working liquid position in the liquid line, is the boundary, dividing the liquid film flow and the single phase liquid flow.

Corresponding to the above three positions, there are two heights. The first height, ΔH , the level difference between the working liquid position of the liquid line and the equivalent working liquid position of the operating evaporator. This is believed to be the driving force of the whole loop thermosyphon. It is mentioned most commonly in some papers (Chen et al., 1986). And the second height, ΔH_l , is the position difference between the initial filling position and the operating position in the liquid line. This height can be measured by experiment, so it is of significance.

For the equivalent working liquid position in the evaporator, as illustrated in Figure 9, the equivalent heights H_l are orders of 200 mm for the calculated heat flux range. H_l will decrease with heat flux, nearly is a linear relation. That is, the higher heat flux need less working fluid in the evaporator. And the inner diameter of the heating tube also exerts influences on the height. If the diameter is replaced from 26 mm to 20 mm, then the equivalent height will be increased about 0.05m.

Fig. 9 Equivalent working liquid height of vapor-liquid mixture in evaporator

As shown in Figure 10, the level difference between the working liquid position of the liquid line and the equivalent working liquid position of the operating evaporator, ΔH versus heat flux is presented. All the calculated ΔH are less than 10mm, this reflects the smaller flow resistance. So, the two-phase loop thermosyphon can transfer larger power. For a certain working temperature, ΔH will increase with heat flux, this reflects the increment of the driving force. If the heat flux is higher, then the driving force will be affected by the working temperature a lot. The higher is the temperature, the bigger driving force. The higher temperature corresponds to the higher pressure. The higher pressure means the vapor is less expanded, there is less flow resistance. So, the driving force ΔH can be smaller.

Fig. 10 The level difference ΔH , as a function of heat flux

The position difference ΔH_i , versus heat flux is demonstrated in Figure 11. The position difference between the initial filling position and the operating position in the liquid line will increase then decrease with heat flux. The loci are nearly parabolic. The maximum of ΔH_i will increase with temperature and will occur at the higher heat flux. Further, for one heat flux, the higher temperature corresponds to the bigger liquid level decrease, ΔH_i is bigger. These results are due to the actions of total flow resistance, physical properties.

Fig. 11 The position difference, between the initial filling position and the operating position in the liquid line, ΔH_i , versus heat flux

4. CONCLUSIONS

The two-phase loop thermosyphon is analyzed theoretically. The evaporator is modeled to describe the flow and heat transfer of liquid and bubbles. The flow and heat transfer of the condenser, the vapor and liquid lines are considered theoretically together with the evaporator. By calculation, some important results are obtained as the following.

(1) For the operating evaporator, the density of the vapor-liquid mixture at the exit is not that of the vapor. The vapor velocity curve of different heat flux is the same, the maximum bubble velocity is 2.68m/s. And the liquid velocity is three orders quantity less than that of the vapor, the liquid flow velocity can nearly be neglected.

(2) The obtained equivalent heights H_i are orders of 200 mm or so for the calculated heat flux range. In order to guarantee that no dry-out point occurs, the heat flux should be less one boundary limit to the evaporator.

(3) The level difference ΔH , between the working liquid position of the liquid line and the equivalent working liquid position of the operating evaporator, stands for the driving force of the whole loop. All the calculated ΔH are less than 10mm, this reflects the smaller flow resistance. The two-phase loop thermosyphon can transfer larger power due to the smaller driving force needed. And the condenser need not be placed much higher than the evaporator.

(4) The total height drop ΔH_i , of the liquid line before and after the loop operating, are orders of several tens of millimeters for the calculated heat flux range.

ACKNOWLEDGEMENTS

The author thanks Prof. Jifu Liu from Harbin Institute of Technology for his suggestions and project support about this work.

NOMENCLATURE

A	area of cross-section (m ²)
C	coefficient of flow resistance(/)
d	diameter(m or mm)
h_{fg}	latent heat of phase change (J/kg)
H	height (m or mm)
l	length(m)
$\dot{m}$	mass flux(kg/s)
p	pressure(Pa)

P	perimeter(m)
q	heat flux (W/m^2 , or kW/m^2)
R	bubble radius(m)
Re	Reynolds number(/)
s, x	coordinate (m)
t	time (s)
T	temperature ($^{\circ}\text{C}$)
u	velocity (m/s)
V	volume(m^3)
W	parameter defined by equation (13)

Greek Symbols

δ	liquid film thickness (m)
ρ	density (kg/m^3)
ξ	coefficient of local flow resistance
τ	shear stress(N/m^2)

Subscripts

c	condenser
e	evaporator
f	flow, friction
in	inner
m	momentum
t	total
δ	liquid film surface
v	vapor
l	liquid

REFERENCES

- Chen K. S., 1988, "Steady-state Analysis of Two Phase Natural Circulation Loop," *International Journal of Heat and Mass Transfer*, **31**(5), 931-940.
[doi:10.1016/0017-9310\(88\)90082-8](https://doi.org/10.1016/0017-9310(88)90082-8)
- Chen Y., Gao M. and Xin M., 1986, "Experiments of Heat Transfer Performance of Separate Type Thermosyphon," *Proceedings of International Heat Pipe Symposium, Osaka, Japan*.
- He J., Ma T. and Zhang Z., 1992, "Heat Transfer Characteristics in the Evaporator Section of a Two-phase Closed Thermosyphon," Advances in Heat Pipe Science and Technology, *Proceedings of the 8th International Heat Pipe Conference*, International Academic Publishers, 335-340.
- Huang B. J., 1988, "Heat Transfer Behavior of a Rectangular Thermosyphon Loop," *Journal of Heat Transfer*, **110**, 437-493
[doi:10.1115/1.3250512](https://doi.org/10.1115/1.3250512)
- Liu X., 1988, "Effect of the Filling Ratio of Working Fluids on the Characteristics of the Two-phase Closed Thermosynpon," Advances in Phase Change Heat Transfer, *Proceedings of International Symposium on Phase Change Heat Transfer*, Chongqing, Sichuang China, 551-556.
- Roesler S., 1991, "Performance and Performance Limitations of Closed Two-phase Thermosyphons", *Proceedings of the International Symposium on Heat Pipe Research and Application*, Shanghai China, Japan Association for Heat Pipes, 50-68.